BACKFLOW ASSEMBLY TEST REPORT

☐ NEW
☐ EXISTING
☐ REPLACEMENT

PREMISE OWNER: _____ PHONE: _____
MAILING ADDRESS: _____
CITY: _____ STATE _____ ZIP _____
ASSEMBLY ADDRESS: _____
ASSEMBLY TYPE: _____ ASSEMBLY LOCATION: _____
MAKE: _____ MODEL: _____ SIZE: _____
WATER PURVEYOR: City of Medical Lake SERIAL NUMBER: _____

	REDUCED PRESSURE ASSEMBLY		PRESSURE VACUUM BRKR/ SPILL-RES VACUUM BRKR		INITIAL TEST
		DOUBLE CHECK	AIR INLET	CHECK	
TEST RESULTS	#1 CHECK PRESS DROP _____ (A) RELIEF VALVE OPENS AT _____ (B) (MIN 2 PSID) BUFFER (A) – (B) = _____ (MIN 3 PSI RECOMMENDED) RELIEF VALVE PASSED ☐ FAILED ☐	CHECK #1 TIGHT ☐ _____ PSID LEAKED ☐ CHECK #2 TIGHT ☐ _____ PSID LEAKED ☐	OPENED AT: _____ PSID DID NOT OPEN ☐	PRESSURE DROP _____ PSID FAILED ☐	PASSED ☐ FAILED ☐ DATE: _____ / / _____ SYSTEM PSI _____

COMMENTS & NOTES	

	REDUCED PRESSURE ASSEMBLY		PVBA./SVBA		RE-TEST AFTER REPAIR DATE:
	#1 CHECK	DCVA	AIR INLET	CHECK	
RE-TEST AFTER REPAIRS	PRESS DROP _____ (A) RELIEF OPENED _____ (B) MIN 2 PSID BUFFER (A)–(B) = _____ MIN 3 PSI	CHECK #1 TIGHT ☐ _____ PSID CHECK #2 TIGHT ☐ _____ PSID	OPENED AT _____ PSID	PRESS DROP _____ PSID	_____ / / _____ PASSED ☐

GAUGE CALIBRATION DATE: _____ DETECTOR METER READING _____

TESTER SIGNATURE _____ TESTER CERT # _____
TESTERS NAME PRINTED _____ GAUGE # _____
TESTERS ADDRESS _____ PHONE # _____
COMPANY NAME _____
☐ WATER RESTORED ?
REPORT RECEIVED BY: _____ (REPRESENTATIVE OF OWNER)

City of Medical Lake's List of Backflow Assembly Testers (BAT)

The following list of Washington State Certified Backflow Assembly Testers is those that have allowed the City of Medical Lake to include them on our list. This is just a partial list of testers in the area who are qualified to test backflow devices. ***We suggest securing several estimates of cost of testing your backflow assembly(s) and do they also repair assemblies if they fail?***

1. Affordable Home Irrigation 1913 S. Garfield Rd. Airway Heights, WA 99001 499-5224
   Val Hilzendeger/B5070 Robert Hilzendeger/ B995 Nicholas Hilzendeger/ B5994

2. Auto-Rain Sprinkler 2938 N. Martin Spokane, WA 99207 487-3430
   Michael S. Neumiller/B4744 , Justin A. Joy

3. B&B Sprinklers P.O. Box 520 Mead, WA 99021 466-7550
   Thomas T. Carney/B5906,

4. Ben's Backflow Testing 14 S. Wheatland St. Medical Lake, WA 99022 385-8061
   Ben Davis/B5479,

5. Dew Drop Sprinklers & Landscaping 11827 E. Trent Ave. Spokane, WA 99206 922-7168
   Greg J. Au/B4738

6. Gold Seal Mechanical 5524 E. Boone Ave. Spokane, WA 99212 535-5944
   Brian Stranger/B1005, Travis B. Curl/B4594, Marc E. Koppang/B5483

7. Heads Up Sprinklers, Inc. 12206 E. 27th Ave. Spokane Valley, WA 99206 926-0917
   Stan G. Strang/B2933

8. Lilac City Sprinklers P.O. Box 141768 Spokane, WA 99214 922-8900
   Tim Burger/B0800
   Robert Bro/B5447

9. AALL – Rite Services P.O. Box 85 Elk, WA 99009 991-4926
   Scott D. Whitmer/B4465

10. Patriot Fire Protection, Inc. 10005 E. Montgomery Spokane Valley, WA 99206 926-3428
    Bryan S. Gordon/B4985, Jason Franz/B4692, Kenneth Hunley/B5492, Anthony L. Hert/B4036
    Wayne M. Gordon/B5725, Aaron L. Mauzay/B4485