

BACKFLOW ASSEMBLY TEST REPORT

<input type="checkbox"/>	NEW
<input type="checkbox"/>	EXISTING
<input type="checkbox"/>	REPLACEMENT

PREMISE OWNER: _____ PHONE: _____
 MAILING ADDRESS: _____

CITY: _____ STATE _____ ZIP _____
 ASSEMBLY ADDRESS: _____

ASSEMBLY TYPE: _____ ASSEMBLY LOCATION: _____

MAKE: _____ MODEL: _____ SIZE: _____
 WATER PURVEYOR: _____ SERIAL NUMBER: _____

TEST RESULTS	REDUCED PRESSURE ASSEMBLY		PRESSURE VACUUM BRKR/ SPILL-RES VACUUM BRKR		INITIAL TEST
			DOUBLE CHECK		PASSED <input type="checkbox"/>
	#1 CHECK PRESS DROP _____ (A) RELIEF VALVE OPENS AT _____ (B) (MIN 2 PSID) BUFFER (A) - (B) = _____ (MIN 3 PSI RECOMMENDED) RELIEF VALVE PASSED <input type="checkbox"/> FAILED <input type="checkbox"/>	CHECK #1 TIGHT <input type="checkbox"/> _____ PSID LEAKED <input type="checkbox"/> _____	AIR INLET OPENED AT: _____ PSID	CHECK PRESSURE DROP _____ PSID FAILED <input type="checkbox"/>	FAILED <input type="checkbox"/> DATE: _____ / ____ / ____ SYSTEM PSI _____
			CHECK #2 TIGHT <input type="checkbox"/> _____ PSID LEAKED <input type="checkbox"/> _____	DID NOT OPEN <input type="checkbox"/>	

COMMENTS & NOTES

RE-TEST AFTER REPAIRS	REDUCED PRESSURE ASSEMBLY		PVBA./SVBA		RE-TEST AFTER REPAIR DATE:
			DCVA		_____ / ____ / ____
	#1 CHECK PRESS DROP _____ (A) RELIEF OPENED _____ (B) MIN 2 PSID BUFFER (A)-(B) = _____ MIN 3 PSI	CHECK #1 TIGHT <input type="checkbox"/> _____ PSID	AIR INLET OPENED AT _____ PSID	CHECK PRESS DROP _____ PSID	PASSED <input type="checkbox"/>
			CHECK #2 TIGHT <input type="checkbox"/> _____ PSID		

GAUGE CALIBRATION DATE: _____ DETECTOR METER READING _____

TESTER SIGNATURE _____ TESTER CERT # _____

TESTERS NAME PRINTED _____ GAUGE # _____

TESTERS ADDRESS _____ PHONE # _____

COMPANY NAME _____

REPORT RECEIVED BY: _____ (REPRESENTATIVE OF OWNER) WATER RESTORED ?

City of Medical Lake's List of Backflow Assembly Testers (BAT)

This list is provided as a convenience to our customers, and it may not include all available Backflow Assembly Testers. We do not recommend or guaranty any testers. It is your responsibility to verify proper and current certification and other licensing requirements before hiring anyone to perform work on your premises.

AALL-Rite Services 4351 Allen Rd. / P.O. Box 85 Elk, WA 99009 (509) 991-4926
Scott D. Whitver

Affordable Home Irrigation 1913 S. Garfield Rd. Airway Heights, WA 99001 (509) 499-5224
Val Hilzendeger Tyler Hilzendeger

Aqua Pro Sprinkler 808 W. Woodway Ave. Spokane, WA 99218 (509) 990-8766
Scott K. Haisley

MAC Backflow Testing 2332 W. Rockwell Ave. Spokane, WA 99205 (509) 599-6314
& Repair
Marty Coleman

Roe Backflow Testing 1716 E. Francis Spokane, WA 99208 (509) 484-0225
William J. Roe