

BACKFLOW ASSEMBLY TEST REPORT

<input type="checkbox"/>	NEW
<input type="checkbox"/>	EXISTING
<input type="checkbox"/>	REPLACEMENT

PREMISE OWNER: _____ PHONE: _____
 MAILING ADDRESS: _____

CITY: _____ STATE _____ ZIP _____
 ASSEMBLY ADDRESS: _____

ASSEMBLY TYPE: _____ ASSEMBLY LOCATION: _____

MAKE: _____ MODEL: _____ SIZE: _____
 WATER PURVEYOR: _____ SERIAL NUMBER: _____

TEST RESULTS	REDUCED PRESSURE ASSEMBLY		PRESSURE VACUUM BRKR/ SPILL-RES VACUUM BRKR		INITIAL TEST	
			AIR INLET	CHECK	PASSED <input type="checkbox"/>	
	DOUBLE CHECK				FAILED <input type="checkbox"/>	
#1 CHECK PRESS DROP _____ (A) RELIEF VALVE OPENS AT _____ (B) (MIN 2 PSID) BUFFER (A) - (B) = _____ (MIN 3 PSI RECOMMENDED) RELIEF VALVE PASSED <input type="checkbox"/> FAILED <input type="checkbox"/>		CHECK #1 TIGHT <input type="checkbox"/> _____ PSID LEAKED <input type="checkbox"/> _____ CHECK #2 TIGHT <input type="checkbox"/> _____ PSID LEAKED <input type="checkbox"/> _____		OPENED AT: _____ PSID DID NOT OPEN <input type="checkbox"/>	PRESSURE DROP _____ PSID FAILED <input type="checkbox"/>	DATE: _____ / _____ / _____ SYSTEM PSI _____

COMMENTS & NOTES

RE-TEST AFTER REPAIRS	REDUCED PRESSURE ASSEMBLY		PVBA./SVBA		RE-TEST AFTER REPAIR DATE:
			AIR INLET	CHECK	PASSED <input type="checkbox"/>
	DCVA				
#1 CHECK PRESS DROP _____ (A) RELIEF OPENED _____ (B) MIN 2 PSID BUFFER (A)-(B) = _____ MIN 3 PSI		CHECK #1 TIGHT <input type="checkbox"/> _____ PSID CHECK #2 TIGHT <input type="checkbox"/> _____ PSID		OPENED AT _____ PSID PRESS DROP _____ PSID	

GAUGE CALIBRATION DATE: _____ DETECTOR METER READING _____

TESTER SIGNATURE _____ TESTER CERT # _____

TESTERS NAME PRINTED _____ GAUGE # _____

TESTERS ADDRESS _____ PHONE # _____

COMPANY NAME _____

REPORT RECEIVED BY: _____ (REPRESENTATIVE OF OWNER) WATER RESTORED ?

City of Medical Lake's List of Backflow Assembly Testers (BAT)

This list is provided as a convenience to our customers, and it may not include all available Backflow Assembly Testers. We do not recommend or guaranty any testers. It is your responsibility to verify proper and current certification and other licensing requirements before hiring anyone to perform work on your premises.

Affordable Home Irrigation 1913 S. Garfield Rd. Airway Heights, WA 99001 (509) 499-5224
Val Hilzendeger Tyler Hilzendeger Nicholas Hilzendeger

Auto Rain Contracting 2938 N. Martin St. Spokane, WA 99207 (509) 487-3430
Kurtis Kanenwischer

Auto Rain Sprinkler 2938 N. Martin St. Spokane, WA 99207 (509) 487-3430
Mike Neumiller

B&B Sprinklers, Inc. 3003 E. Farwell Rd./Box 520 Mead, WA 99021 (509) 466-7550
Thomas Carney

DW Landscape 3110 E. Chattaroy Rd. TRLE 43 Chattaroy, WA 99003 (509) 999-5829
Dustin Wickham

Lilac City Sprinklers P.O. Box 141768 Spokane, WA 99214-1768 (509) 922-8900
Tim Burger (509) 742-3004

MAC Backflow Testing 2332 W. Rockwell Ave. Spokane, WA 99205 (509) 599-6314
& Repair
Marty Coleman